

Office of The Chief Medical Officer, Ghaziabad

Ref.No. DSO/IDSP/2023/ 1762

Dated 18/04/2023

PORTABLE WATER TEST REPORT

ADDRESS:- NEW ERA SCHOOL 318, 345 PANDAV NAGAR, GHAZIABAD.

No of sample collected : 02

Date of sample collected : 12-04-2023

Sample collection area

Sample collection area	Sample ID	Result
NEW ERA SCHOOL 318 PANDAV NAGAR GHAZIABAD.	533	Satisfactory
NEW ERA SCHOOL 318,345 PANDAV NAGAR GHAZIABAD.	534	Satisfactory

Test Result

H₂S Water test kit : Negative (-Ve) after 24-48 hrs incubation


Comments:-


H₂S water test kit report - ve reflects that water is free from Coliforms Organism.

Recommendation:

Given water sample safe for drinking purpose.


Lab Technician
IDSP Lab
Ghaziabad


(Dr. Suruchi Saini)
Microbiologist IDSP Lab
Ghaziabad


(Dr R.K Gupta)
District Public Health Expert
District Surveillance Officer
District Public Health Expert
District Ghaziabad

Office of The Chief Medical Officer, Ghaziabad

Ref.No: DSO/IDSP/2023/ 1762

Dated 18-04-2023

Safe Drinking Water, Health & Hygiene Certificate

It is certified that a combined inspection team headed by Mr. Sujit Kumar Rai from IDSP UNIT, Ghaziabad and Nagar Nigam Ghaziabad inspected the premises NEW ERA SCHOOL 318 PANDAV NAGAR GHAZIABAD & NEW ERA COLLAGE(CANTEEN) 318,345 PANDAV NAGAR GHAZIABAD on 12-04-2023 and found NEW ERA SCHOOL 318 PANDAV NAGAR GHAZIABAD & NEW ERA COLLAGE(CANTEEN) 318, 345 PANDAV NAGAR GHAZIABAD has safe Drinking water facilities for the person is maintaining hygienic sanitation conditions in the water as per the norms. This certificate is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand canceled on proof.

Based on Ref: DSO/IDSP/2023/ 1762

(Dr. R K Gupta)

District Public Health Expert

Ghaziabad
District Surveillance Officer
District Public Health Expert
District Ghaziabad

To

NEW ERA SCHOOL 318 PANDAV NAGAR
GHAZIABAD &
NEW ERA COLLAGE(CANTEEN) 315 PANDAV NAGAR
GHAZIABAD